

Name of work:- Beautification of Gandhi Maidan Phase - 1
NIT No:- BUIDCo/ Yo- 541 / 14-22 Date:- 27.04.2017

Prat
~~Addendum-1~~ pre-bid query reply

442

Sr. No.	Bid Condition	Queries from Bidders	Reply
1	Supplying & erection of 20 meter high mast in two section hot dip galvanize with raising lowering system , including other accessories as galvanize luminaries carriage with twelve arms suitable to install the luminaries in symmetrical arrangement, head frame, double drum winch ,6mm dia ss wire rope, trailing cable, connector ,integral power tool motor manual handle, junction box, lightning finial, Twin dome aviation obstruction light, foundation bolt made of special speed steel red oxide coated along with nuts, washer, template and anchor plate ,non integral flood light luminaries cat. no BJENF 24 Bajaj make (2X400w) 12 Nos, along with control gear box, Out door stand mounted feeder pillar control panel with 63A TPN incomer , single dial time switch, 45A TP contractor for automatic switching of luminaries, power tool control, for systematic operation of mast ,GI pipe earthing 2 No and proper connection with 25x3 mm GI strip to high mast earth terminal and feeder pillar including providing foundation with M25 grade concrete for high mast considering the safe soil bearing capacity as per site and design testing commissioning of high mast lighting system etc as required.	Non Schedule Item sr. no. 5, it is mentioned ref no. BJENF24 Bajaj make (2x400) w flood light. This light is of Non Conventional type (HPSV or MHL) type suitable flood light. But as per consultation to department there is to be led light type flood. So its a kind request please clarify this confusion that which type of fitting is there to be installed.	Please refer Addendum-1 sr. no. 3, Led flood light of BIS make is to be installed.
2	Supplying of decorative Led Light Pole of approved brand as shown in uploaded pic with cast iron street light pole double arm bracket with approved colour of 9 meter height complete etc. as per direction of E/I.	The snap of poles and light (decorative type) which is posted on NIT of tender is actually of Bajaj Make but it is showing Dwarika India regarding which when enquiry done it is not found any pole manufacturing company	The shape and aesthetic view of the pole is shown in the pic. The make may be of any BIS marked company.
3	(a) Satisfactorily completed as a prime contractor (or as a nominated subcontractor, where the subcontract involved execution of all main items of work described in the bid document, provided further that all other qualification criteria are satisfied) at least one similar work (Construction of park) of value not less than amount indicated in Appendix (usually not less than 10% (ten percent) of estimated value of contract.	satisfactory completed as a prime contractor of Belsand Bus Stand under your flag ship.....	Please refer Addendum-1 sr. no. 5, similar work will be a project consist of supply, laying of Chequerred Tile and Paver Block having its value not less than Rs. 28,35,049/-.
4	Bid Submission date	Request you to kindly extend the bid submission date by another 10 days.	Please refer corrigendum - 2
5	S/F/F of street light fitting Model Borage crown of approved brand by E/I along with 90 watt Led Light suitable for 250 volts 50HZ with proper connection with 1.5 sq.mm PVC insulated copper conductor wire testing and commissioning etc. as required.	You are requested to mention model number of light	The model of light should be any BIS make but resemble with the picture uploaded.
6	Supplying & laying of dust free Washed Moorum at site including loading, unloading & carriage as per direction of E/I	Morrum is not permitted by Mining Department	IF morrum will not be avialable, the necessary direction will be given during execution
7		Kindly clarify regarding the foundation for street light pole.	The execution of foundation is included in Schedule - A (SOR Items). Regarding this kindly refer Addendum sr. no. 4
		The rate for 60 mm thick paver block is less than the SOR rate. Kindly clarify	The rate mentioned in the BOQ is as per BCD 2016, Item no. 11.77

Pr
27/5/2017