

Pre-Bid Reply

Name of Work: Kahalgaon I&D and STP Project

NIT.No: BUIDCo/Yo-1492/20-173, Dated-01.09.2020

| S.No | Query | BUIDCo Reply |
|------|-------|--------------|
|------|-------|--------------|

Bidder Name: A.R Enterprises

| 1 | <p>How design of STP without having data of characteristics of inflow sewage can be done?</p> | <p>The tentative inlet sewage parameter for different drains are mentioned below. These values are only for reference. Bidders have to asses inlet sewage parameter based on their own field survey.</p> <table border="1" style="margin-left: auto; margin-right: auto; border-collapse: collapse; text-align: center;"> <thead> <tr> <th colspan="8">Quality of raw sewage carried by different drains at Kahalgaon</th> </tr> <tr> <th>Parameters</th> <th>Kagzi Tolana</th> <th>Kali Ghat nala</th> <th>Purani Bazarna</th> <th>Grave Yard nala</th> <th>Bus Stand nala</th> <th>Sidhi Ghat nala</th> <th>Sati Ghat nala</th> </tr> </thead> <tbody> <tr> <td>pH</td> <td>6.90</td> <td>7.0</td> <td>6.80</td> <td>6.70</td> <td>6.70</td> <td>7.00</td> <td>6.80</td> </tr> <tr> <td>SS, mg/l</td> <td>380</td> <td>340</td> <td>390</td> <td>385</td> <td>385</td> <td>340</td> <td>390</td> </tr> <tr> <td>BOD, mg/l</td> <td>138</td> <td>120</td> <td>130</td> <td>125</td> <td>125</td> <td>120</td> <td>130</td> </tr> <tr> <td>COD, mg/l</td> <td>250</td> <td>225</td> <td>253</td> <td>255</td> <td>255</td> <td>225</td> <td>253</td> </tr> </tbody> </table> | Quality of raw sewage carried by different drains at Kahalgaon | | | | | | | | Parameters | Kagzi Tolana | Kali Ghat nala | Purani Bazarna | Grave Yard nala | Bus Stand nala | Sidhi Ghat nala | Sati Ghat nala | pH | 6.90 | 7.0 | 6.80 | 6.70 | 6.70 | 7.00 | 6.80 | SS, mg/l | 380 | 340 | 390 | 385 | 385 | 340 | 390 | BOD, mg/l | 138 | 120 | 130 | 125 | 125 | 120 | 130 | COD, mg/l | 250 | 225 | 253 | 255 | 255 | 225 | 253 |
|--|---|--|--|-----------------|----------------|-----------------|----------------|--|--|--|------------|--------------|----------------|----------------|-----------------|----------------|-----------------|----------------|----|------|-----|------|------|------|------|------|----------|-----|-----|-----|-----|-----|-----|-----|-----------|-----|-----|-----|-----|-----|-----|-----|-----------|-----|-----|-----|-----|-----|-----|-----|
| Quality of raw sewage carried by different drains at Kahalgaon | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Parameters | Kagzi Tolana | Kali Ghat nala | Purani Bazarna | Grave Yard nala | Bus Stand nala | Sidhi Ghat nala | Sati Ghat nala | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| pH | 6.90 | 7.0 | 6.80 | 6.70 | 6.70 | 7.00 | 6.80 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| SS, mg/l | 380 | 340 | 390 | 385 | 385 | 340 | 390 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| BOD, mg/l | 138 | 120 | 130 | 125 | 125 | 120 | 130 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| COD, mg/l | 250 | 225 | 253 | 255 | 255 | 225 | 253 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |

| | | |
|---|---|---|
| 2 | <p>Requirement of Treated water quality as mentioned in clause 2.4 are different as mentioned in clause 13.1.11. under the heading "Design Responsibilities" in the bid document of STP, Kahalgaon. Clarification needed in this context.</p> | <p>Parameters are same. Bid conditions shall prevail.</p> |
|---|---|---|

| | | |
|---|--|---|
| 3 | <p>What is the meaning of word "Tooner" mentioned at sl. 17 in drawing no. TAHAL/SPUR/I & D/KNP/09 under heading CHLORINATION CUM CHLORINE TOONER HOUSE in bid document of STP, Kahalgaon?</p> | <p>Pease read "Tooner" word as "Tonner"</p> |
|---|--|---|

| | | |
|---|---|------------------------------------|
| 4 | <p>Price Variation is not applicable for these Contracts, As the Contract Period is 1 Year (Construction) + 15 Years (O&M), So we request you to kindly make Price Variation applicable for these Projects.</p> | <p>Bid condition shall prevail</p> |
|---|---|------------------------------------|